

# Auxiliary contact module; 1 N/0 + 1N/C; laterally outside; screw connection

Powering Business Worldwide\*

Part no. DILM1000-XHI11-SA
Article no. 278427
Catalog No. XTCEXSCN11

Product range			Accessories
Accessories			Auxiliary contact modules
Description			with interlocked opposing contacts
Function			for standard applications
Number of poles			2 pole
Connection technique			Screw terminals
Rated operational current			
Conventional free air thermal current, 1 pole			
Open			
at 60 °C	$I_{th} = I_e$	Α	10
AC-15			
220 V 230 V 240 V	I <sub>e</sub>	Α	6
380 V 400 V 500 V	I <sub>e</sub>	Α	4

1 N/0

1 NC

Side mounted

DILM40 - DILM225A

DILMP63 - DILMP200

#### **Technical data**

**Contacts** 

Mounting type

For use with

Contact sequence

N/0 = Normally open

N/C = Normally closed

#### **Electrical specifications for standard auxiliary contacts**

		Yes
		DILM40 - DILM225A
$U_{\text{imp}}$	kV	6
		III/3
Ui	V AC	690
U <sub>e</sub>	V AC	500
	V AC	440
	V AC	440
	V AC	440
	Α	
I <sub>th</sub> =I <sub>e</sub>	Α	10
le	Α	6
	$\begin{array}{c} U_{i} \\ U_{e} \\ \\ I_{th} = I_{e} \\ \\ \end{array}$	U <sub>imp</sub> kV  U <sub>i</sub> VAC  U <sub>e</sub> VAC  VAC  VAC  VAC  A

380 V 400 V 500 V	I <sub>e</sub>	Α	4
DC current			
DC-13 (6xP)			
24 V	Ie	Α	3
60 V	I <sub>e</sub>	Α	1.5
110 V	le	Α	0.8
220 V	I <sub>e</sub>	Α	0.3
omponent lifespan			
at U <sub>e</sub> = 230 V, AC-15, 3 A	Operations	x 10 <sup>6</sup>	1.3
hort-circuit rating without welding			
max. fuse		A gG/gL	16
ated conditional short-circuit current 500 V	Iq	kA	1
erminal capacity control circuit cables			
olid		mm <sup>2</sup>	1 x (0.75 - 2.5) 2 x (0.75 - 2.5)
exible with ferrule		mm <sup>2</sup>	1 x (0.75 - 2.5) 2 x (0.75 - 2.5)
olid or stranded		AWG	18 - 14
erminal screw			M3.5
ghtening torque		Nm	1.2
ool			
ontrol circuit cables			
Pozidriv screwdriver		Size	2
Standard screwdriver		mm	0.8 x 5.5 1 x 6

#### **Design verification as per IEC/EN 61439**

Design verification as per IEG/EN 01439			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	4
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0.11
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	0
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	60
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.

10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)			
Electric engineering, automation, process control engineering / Low-voltage switch (ecl@ss8.1-27-37-13-02 [AKN342010])	n technology / C	omponen	t for low-voltage switching technology / Auxiliary switch block
Number of contacts as change-over contact			0
Number of contacts as normally open contact			1
Number of contacts as normally closed contact			1
Rated operation current le at AC-15, 230 V		Α	6
Type of electric connection			Screw connection
Model			Top mounting
Mounting method			Side mounting

### Approvals

• •	
Product Standards	IEC/EN 60947-4-1; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-04
North America Certification	UL listed, CSA certified
Specially designed for North America	No

## Additional product information (links)

IL03407034Z (AWA2100-2251) Auxiliary contact	
IL03407034Z (AWA2100-2251) Auxiliary contact	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL03407034Z2010_10.pdf
UL/CSA: Approved rating data	http://de.ecat.moeller.net/flip-cat/?edition=HPLTE&startpage=5.84
Switchgear of Power Factor Correction Systems	http://www.moeller.net/binary/ver_techpapers/ver934en.pdf
X-Start - Modern Switching Installations Efficiently Fitted and Wired Securely	http://www.moeller.net/binary/ver_techpapers/ver938en.pdf
Mirror Contacts for Highly-Reliable Information Relating to Safety-Related Control Functions	http://www.moeller.net/binary/ver_techpapers/ver944en.pdf
Effect of the Cabel Capacitance of Long Control Cables on the Actuation of Contactors	http://www.moeller.net/binary/ver_techpapers/ver949en.pdf
Motor starters and "Special Purpose Ratings" for the North American market	http://www.moeller.net/binary/ver_techpapers/ver953en.pdf
Switchgear for Luminaires	http://www.moeller.net/binary/ver_techpapers/ver955en.pdf
Standard Compliant and Functionally Safe Engineering Design with Mechanical Auxiliary Contacts	http://www.moeller.net/binary/ver_techpapers/ver956en.pdf
The Interaction of Contactors with PLCs	http://www.moeller.net/binary/ver_techpapers/ver957en.pdf
Busbar Component Adapters for modern Industrial control panels	http://www.moeller.net/binary/ver_techpapers/ver960en.pdf